

2017 SHEEPVENTION GAS SAFETY CHECK LIST

NB: ONLY REQUIRED FOR THOSE SITES THAT WILL BE USING GAS APPLIANCES

ABN: 12 274 345 626

HAMILTON P & A SOCIETY, P.O. BOX 276, HAMILTON, VIC. 3300

GAS SAFETY CHECK LIST

This check list is for use by exhibitors and authorised personnel. The check list should form part of the exhibitors safety plan. This check list should be kept at hand for viewing by authorities and safety officers.

Event name :

Exhibitors name:

Exhibiting as:

.....

Site Number: Mobile Catering Vehicle Compliance Number:

Exhibitors signature: Date:

	YES	NO	ACTION IF 'NO'
APPLIANCES			
Only certified appliances in use and proof of certification can be provided for each appliance	[]	[]
Service History be provided for each appliance?	[]	[]
All gas appliances in good working order	[]	[]
Safety devices not tampered with	[]	[]
All appliance taps and knobs clearly marked and in good condition	[]	[]
All portable gas appliances are correctly secured and placed on non-combustible surfaces	[]	[]
All portable and installed gas appliances are located in a well vented location	[]	[]
All portable and installed gas appliances have clearance from LPGas Cylinders	[]	[]
Appliances pressures does not exceeding 3kPa	[]	[]
Appliance numbers match appropriate supply cylinders	[]	[]
The consumer piping in good condition	[]	[]
All hoses in use are in good condition and meet safety standards	[]	[]
REGULATORS			
All regulators in good condition	[]	[]
Regulator hose is made of approved material	[]	[]
Regulator hose is in Good Condition	[]	[]
All regulators in use are protected from accidental damage	[]	[]
Regulator hose is less than 3m in length	[]	[]
CYLINDERS			
All cylinders to be used are within 10 years of the last test date	[]	[]
All cylinders to be used in good condition	[]	[]
All cylinder connections been checked for leaks	[]	[]
All cylinders to be used stable and correctly secured	[]	[]
All cylinders to be used located away from flammable materials and ignition sources	[]	[]
All cylinders are not blocking of exit and travel paths	[]	[]
Cylinders quantity has not been exceeded for the structure type	[]	[]
Cylinders size has not been exceeded for the structure type	[]	[]

Exhibitor sites will be subject to inspection/audit by Sheepvention OHS Management and may be subject to inspection by Work Safe Victoria and Energy Safe Victoria inspectors at any time prior to and during the event.